

Certificate of Conformity of the Factory Production Control 2195-CPR-1505601

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Cold formed welded structural hollow sections of non-alloy steels made of the following steel grades

(tested for performance for the characteristics described in Annex 1 which is an inseparable part of this certificate)

produced by the manufacturer

YÜCEL BORU VE PROFİL ENDÜSTRİSİ A.Ş.

Rıhtım Caddesi No:44 Kadıköy / İstanbul – Turkey

and produced in the manufacturing plant

YÜCEL BORU VE PROFİL ENDÜSTRİSİ A.Ş.

**Büyük Tüysüz Mahallesi Vali Kerem Al Caddesi No:8 Tüysüz Beldesi Toprakkale /
Osmaniye – Turkey**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 10219-1: 2006

It is proof that the performance characteristics specified in the audit report numbered CPR-025/26, which is an integral part of this certificate and is annexed to this certificate under system 2+, are implemented and that all requirements of the Factory Production Control determined for these performances are compliant. This certificate was first issued on 25.02.2015, renewed on 25.02.2026 and will remain valid as long as neither the harmonised standard, the construction product, the assessment and verification of constancy of performance methods nor the manufacturing conditions and factory production control in the factory are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit

Validity Date : 25.02.2027

Period Validity Date : 25.02.2027


Rukiye BALKAN
Deputy General Manager



FR. CPR. 24 R:05

Certificate of Conformity of the Factory Production Control

2195-CPR-1505601

Annex 1

Intended uses;

To be used in metal structures or in composite metal and concrete structures.

Controlled Performance Characteristics;

- Dimension and Shape Tolerances,
- Yield Strength,
- Elongation,
- Tensile Strength,
- Impact Strength,
- Weldability.

Certification Scope:

Steel Grade	Section	Dimension
S235JRH S275J0H	Circular hollow sections	Ø from 12,70 mm up to Ø 168,30 mm wall thickness: from 1,15 mm up to 8,00 mm
S275J2H S355J0H	Square hollow sections	from 10 mm x 10 mm up to 125 mm x 125 mm, wall thickness: from 1,15 mm up to 8,00 mm
S355J2H S355K2H	Rectangular hollow sections	from 15 mm x 10 mm up to 100 mm x 150 mm, wall thickness: from 1,15 mm up to 8,00 mm



Rukiye BALKAN
Deputy General Manager

FR. CPR. 24 R:05